


# All Eyes on Fire Safety

## You Can Help... Take the Challenge!



**These fire code violations can cause a fire, contribute to the spread of fire, or delay your evacuation... you can make the difference!**

**IF YOU SEE THIS...**



**DO THIS...**

Remove the door stop.  
Close the door.

Doorstops or wedges being used to hold open a door

**IF YOU SEE THIS...**



**DO THIS...**

Remove.  
Complete a Physical Plant work order to add an outlet

Power strips with circuit breakers are allowed temporarily, except for large appliances which must be plugged directly into a wall outlet.

Extension cord used as a substitute for permanent wiring

**IF YOU SEE THIS...**



**DO THIS...**

Remove.  
Complete a Physical Plant work order to add an outlet.

Unapproved multi-plug adaptors

**IF YOU SEE THIS...**



**DO THIS**

Secure with chain or report to EOHSS by phone or e-mail [ehsshelp@umdnj.edu](mailto:ehsshelp@umdnj.edu).

Unsecured compressed gas cylinders

**IF YOU SEE THIS...**



**DO THIS...**

Remove.  
Call or e-mail EOHSS at [ehsshelp@umdnj.edu](mailto:ehsshelp@umdnj.edu) for information on approved space heaters.

Unapproved/unsafe use of space heater

**IF YOU SEE THIS...**



**DO THIS...**

Remove paper.

Excessive paper accumulation (combustibles)

**IF YOU SEE THIS...**



**DO THIS...**

Report the missing ceiling tile to your campus Physical Plant office.

Missing or improperly placed ceiling tiles

**IF YOU SEE THIS...**



**DO THIS...**

Remove items blocking egress or call or e-mail EOHSS at [ehsshelp@umdnj.edu](mailto:ehsshelp@umdnj.edu).

Blocked fire exit



Newark (973) 972-4812 ♦ Piscataway/New Brunswick (732) 235-4058  
Scotch Plains (908) 889-2486 ♦ Stratford/Camden (856) 566-6189  
Website ♦ <http://www2.umdnj.edu/ehssweb>  
E-mail ♦ [ehsshelp@umdnj.edu](mailto:ehsshelp@umdnj.edu)