

TO: All Bidders
Supply and Deliver Above Ground Diesel Storage Tanks
RFP# P06-028

FROM: Dick Gall, Procurement Specialist
Purchasing Services

SUBJECT: Addendum #1, RFP#P06-028 (Two (2) Pages).
Due Date Change, Revisions to Scope of Work.

DATE: January 4, 2006

Addendum #1 – RFP# P06-028

- 1) Due Date Changed as Follows:
Original Due Date: January 11, 2006 @ 2:00 PM.
New Due Date: February 16, 2006 @ 2:00 PM.
- 2) Price Sheet Section 8.0, Page 42, to remain unchanged. Contractor shall submit pricing for only one (1) type of tank. Total amount to include total capacity of 60,000 U.S. Gallons and delivery to site.
- 3) Section 3.1, Page 10: Change to read: The Contractor shall supply and deliver above ground storage tanks with a total capacity of 60,000 gallons.
- 4) Section 3.7, Page 10: Change to read: The Contractor shall provide and deliver pre-engineered above ground tank systems complete with tank, piping, secondary containment, gauges, and other accessories specified herein as a complete assembled system.
- 5) Attachment A, Page 52. Add the following: H) Access Steps and Ladders: The tanks shall be equipped with access steps or ladders as indicated on the submittal drawings. Steps and ladders shall be of welded steel construction with prime and finish paint of industrial enamel.

Steps and ladders shall be designed to conform to OSHA requirements. Steps shall include non-skid tread surfaces, handrails, platforms, and kick plates as required for OSHA compliance.

- 6) Section 5.7.1, Page 23. Change to read as follows: Each bidder shall hold the price submitted for a minimum of 180 calendar days from the date of final award which is the date of the Contract Term sheet signed by the Executive Director of Materials Management.

End of Addendum #1