

TO: All Bidders
Service of the Safetronics Variable Frequency Drives located in the
International Center for Public Health Building
(Proposal RFP #P06-070)

FROM: Francis G. Palek, Buyer
Purchasing Services

SUBJECT: Addendum #1- RFP# P06-070

DATE: March 1, 2006

Addendum #1
Page# 1 of 2

Item#1 Please change the following sections only:

1.1.1 (Change to) Purpose

This Request for Proposal (RFP) is being issued by the University of Medicine and Dentistry of New Jersey (UMDNJ), Department of Purchasing Services on behalf of the Department of Physical Plant.

The purpose of this RFP is to enter into a contract for the diagnosis and repair of eighteen (18) Safetronics variable frequency drives with the model numbers FP5 and GP5 located in the International Center for Public Health Building, 225 Warren Street, Newark, New Jersey. The work is to include labor, services, material, supplies, tools and equipment.

3.10 (Change to) Maintenance Services

3.10.3 The Contractor must clean the interior of the variable frequency drives as per manufacturers' instructions and verify the thoroughness of the cleaning using an infra-red heat detection device while the drive is in operation.

3.10.4 The Contractor must verify the tightness of all terminals, connectors and mounting hardware.

3.10.5 The Contractor must replace all interior cooling fans.

3.10.6 The Contractor must replace all smoothing capacitors.

3.10.7 The Contractor must inspect and replace all defective interior breakers and relays as needed.

3.10.8 The Contractor must replace all cabinet fuses as needed.

3.10.9 The Contractor must inspect and replace any defective or worn Safetronics variable frequency drive capacitors as needed.

3.10.10 The Contractor must test the Safetronics variable frequency drives under load to verify the drives are operating within manufacturer's specifications.

3.10.11 (Add) The Contractor must replace the cooling fans and clean the interior of the two NEMA 12 enclosures.

3.10.12 (Add) The Contractor may need to replace two (1) seven and a half (7.5) horse power variable frequency drives marked as 8A and 8B.

8.0 (Change to) **PRICE SHEET AND SUPPORTING DETAIL**

RFP# P06-066

Total, firm, fixed cost to provide service for eighteen (18) Safetronics Variable frequency drives located in the International Center for Public Health Building located in Newark, NJ Per Section 3.0 of the RFP.

TOTAL SERVICE PRICE (Excluding Breakers, Relays and Capacitors)	\$ _____ .
UNIT PRICE BREAKERS AND RELAYS	\$ _____ EA.
UNIT PRICE ALUMINUM ELECTROLYTICAL CAPACITORS	\$ _____ EA.
UNIT PRICE SEVEN AND HALF HORSE POWER VARIABLE FREQUENCY DRIVE	\$ _____ EA.

END OF ADDENDUM # 1