

**TO:** All Bidders  
Maintenance and Service of the Fire and Security System in the Education  
& Research Building Camden, New Jersey  
(Proposal RFP #P06-117)

**FROM:** Francis G. Palek, Buyer  
Purchasing Services

**SUBJECT:** Addendum #1- RFP# P06-117

**DATE:** May 10, 2006

---

---

Addendum #1  
Page# 1 of 2

Please change the following sections only:

### 3.0 (Change to) Scope of Work

It is the intent of UMDNJ to engage a certified and experienced Contractor, which shall supply all the personnel and other resources necessary to perform periodic testing and inspection of fire alarm systems in compliance with the most current adopted codes of both the NFPA 72 and the New Jersey Uniform Fire Code. The system is located in the Education & Research Building, 401 Haddon Avenue, Camden, New Jersey.

### 3.3 (Change to) Reports

The Contractor must submit to the Physical Plant Department a certified inspection report that summarizes the tasks completed. The report must be type-written, signed and dated in NFPA Format and include all necessary information required by NFPA and the New Jersey Uniform Fire Code.

### 3.4 (Change to) Testing

3.4.1 The Contractor must perform testing on applicable devices two (2) times per year and supply a written, signed and dated report certifying the test. The certifications and testing, as well as the report, must comply with NFPA 72 and/or the State of New Jersey Uniform Fire Code standards, whichever is more stringent. The Contractor performing the work must employ a person who holds a valid certificate of certification in accordance with applicable New Jersey State Law.

3.4.2 The Contractor may also need to test specific devices as requested by the Physical Plant Project Manager.

3.4.3 UMDNJ will contract with a separate certified fire protection Contractor to assist or perform the required testing of water flow devices and valve tamper/supervisory devices related to water-based systems.

3.7 (Change to) Repairs and Parts

The Contractor must supply a person who is certified by the State of New Jersey to perform system certifications, installations and replacements/repairs to the equipment listed in section 1.2 of the RFP.

3.9 (Change to) Certifications

The Contractor must be certified in Honeywell Sentara Systems and employ people with a valid certificate of certification issued by the State of New Jersey.

**END OF ADDENDUM # 1**